



**TOWN OF NEWBURGH
PLANNING BOARD
TECHNICAL REVIEW COMMENTS**

PROJECT NAME: 273 ROUTE 17K CHANGE OF USE-RESTAURANT
PROJECT NO.: 22-05
PROJECT LOCATION: 273 ROUTE 17K
SECTION 90, BLOCK 6, LOT 1
REVIEW DATE: 31 MARCH 2023
MEETING DATE: 6 APRIL 2023
PROJECT REPRESENTATIVE: A. HENNESSY ARCHITECTS

1. The project proposes a change of use from a former dry cleaning establishment to a restaurant use in the B Zoning District.
2. The Disclosure Statement in the application packet is not executed by the property owner/applicant.
3. The project requires a front yard variance for the existing conditions on NYS Route 17K. the applicants have identified a 40 foot front yard setback, while Section 185-18C(4)(b) identifies that front yards abutting all County and State highways shall be at least 60 feet in depth, except when the majority of existing buildings on either side of the road within 300 feet from the intersection of the nearest property line and street line are lesser average depth. In such case the front yard shall be 50 feet or the average of all lot depths within 300 feet, whichever is greater. Since the applicant requires a variance for a front yard setback, the variance request should be for the 60 feet where 35.7 feet is provided. Front yard setback on the plans should be changed to the 60 foot width at the 17K frontage.
4. Plans should be submitted to the NYS Department of Transportation as property accesses Route 17K.
5. The change of use to a restaurant will require the installation of a grease trap on the sanitary sewer line. Sanitary sewer and water locations should be added to the plans.
6. Plans must be submitted to Orange County Department of Planning.
7. Adjoiner's Notices must be sent in compliance with Town Code.
8. Appropriate accessible parking signage should be provided on the plan and in details.
9. Size of the existing parking spaces should be dimensioned.

NEW YORK OFFICE

33 Airport Center Drive, Suite 202, New Windsor, NY 12553
845-567-3100 | F: 845-567-3232 | mheny@mhepc.com

PENNSYLVANIA OFFICE

111 Wheatfield Drive, Suite 1, Milford, PA 18337
570-296-2765 | F: 570-296-2767 | mhpa@mhepc.com

Respectfully submitted,

MHE Engineering, D.P.C.

A handwritten signature in blue ink that reads "Patrick J. Hines". The signature is written in a cursive style with a large, stylized initial 'P'.

Patrick J. Hines
Principal
PJH/kbw