

PROJECT
**Proposed
Warehouse**


FOR
**YM & YH
Developers, LLC**

REV	DATE	DESCRIPTION


175 10th Street
Belford, NJ 07718
732.908.7232
Pratt-DS.com

RICK PRATT, AIA
NY - 032887-1

ISSUED: 4/19/23
JOB NO: 23006




SD1



1 GROUND FLOOR PLAN
SCALE: 1" = 30'

I:\Users\Rick\Pratt Design Studio Dropbox\Pratt Design Studio, LLC\02-PDS Projects\23006-Jiffy-Newburgh\03 ARCHITECTURE\A CADD\23006-JIFFY.pln



SOLAR READY ROOF
108,000 SF = 41% OF ROOF

1/4" PER FOOT MIN. SLOPE TYPICAL

1/4" PER FOOT MIN. SLOPE TYPICAL

NOTE: ARCHITECT MUST INCLUDE CERTIFICATION THAT DRAWINGS CONFORM WITH SITE PLAN WITH RESPECT TO OUTDOOR FIXTURES AND AMENITIES

PROJECT
**Proposed
Warehouse**


FOR
**YM & YH
Developers, LLC**

REV	DATE	DESCRIPTION

175 10th Street
Belford, NJ 07718
732.908.7232
Pratt-DS.com

RICK PRATT, AIA
NY - 032887-1


ISSUED: 4/19/23
JOB NO: 23006




OVERALL ROOF PLAN


SD2

1 OVERALL ROOF PLAN
SCALE: 1" = 30'






1 NORTH ELEVATION
SCALE: 1" = 30'









2 SOUTH ELEVATION
SCALE: 1" = 30'




NOTE: ARCHITECT MUST INCLUDE CERTIFICATION THAT DRAWINGS CONFORM WITH SITE PLAN WITH RESPECT TO OUTDOOR FIXTURES AND AMENITIES

VIEW TOWARDS OFFICE ENTRY CORNER

- COLORS:**
- PAINT MANUFACTURER:**
SHERWIN WILLIAMS
-  P1 "WHITE" / SW6252 - ICE CUBE
 -  P2 "LIGHT GRAY" / SW7653 - SILVERPOINTE
 -  P3 "MEDIUM GRAY" / SW7658 - GRAY CLOUDS
 -  P4 "DARK GRAY" / SW7660 - EARL GRAY
 -  P5 "DARK BLUE" / SW6517 - REGATTA



3 EAST ELEVATION
SCALE: 1" = 30'



4 WEST ELEVATION
SCALE: 1" = 30'

BUILDING SIGNAGE:

ALLOWED 1 SF PER LF OF STREET FACING BUILDING ELEVATION = 728 SF ALLOWED. 360 SF PROPOSED

PROJECT
Proposed
Warehouse


FOR
YM & YH
Developers, LLC

REV	DATE	DESCRIPTION

175 10th Street
Belford, NJ 07718
732.908.7232
Pratt-DS.com

RICK PRATT, AIA
NY - 032887-1

ISSUED: 4/19/23
JOB NO: 23006



ELEVATIONS

SD3

REV	DATE	DESCRIPTION

175 10th Street
Belford, NJ 07718
732.908.7232
Pratt-DS.com






RICK PRATT, AIA
NY - 032887-1

ISSUED: 4/19/23
JOB NO: 23006




SD4

CROSS SECTIONS & MONUMENT SIGN



I:\Users\Rick\Pratt Design Studio Dropbox\Pratt Design Studio, LLC\02-PDS Projects\23006-Jiffy-Newburgh\03 ARCHITECTURE\A CAD\23006-JIFFY.pln

Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	112 °F	
				Total = 3440							



Hydraulic Information	
Remote Area 1	
OCCUPANCY CLASSIFICATION	ESFR
MIN END HEAD PRESSURE	40.000 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2420.43
TOTAL PRESSURE REQUIRED	7.447
BASE OF RISER (gpm)	1920.43
BASE OF RISER (psi)	105.042
SAFETY MARGIN (psi)	+28.080 (79.3%)

1 SYSTEM 1
0-3/32" = 1 Foot

SYSTEM 1	
Symbol	# OF HEADS
●	340
Total = 340	

SYSTEM #	SYSTEM 9	SYSTEM 8	SYSTEM 7	SYSTEM 6	SYSTEM 5
SYSTEM 1					

KEY PLAN

IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTED LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTING, LABELS, AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

56 GILBERT STREET, SUITE 101
MONROE, NY 10650
845-7810107
INFO@GLOBALFIREUSA.COM
www.globalfireusa.com


DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALLIANCE FIRE PROTECTION INC. (AIFP) GLOBAL FIRE PREVENTION HEREINAFTER KNOWN AS AIFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. AIFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, OR SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL, TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD AIFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THE SYSTEM IN ANY EVENT SHOULD AIFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. AIFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, OR SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
LIC # 079676

PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
ROUTE 300
NEWBURGH, NY

TAX LOT ID: XXX-XX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" UNO.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-1 2 of 12



Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							

Hydraulic Information	
Remote Area 2	
OCCUPANCY CLASSIFICATION	ESFR
MIN END HEAD PRESSURE	40.00 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2420.25
TOTAL PRESSURE REQUIRED	7.621
BASE of RISER (psi)	150.25
BASE of RISER (psi)	152.20
SAFETY MARGIN (psi)	+9.727 (48.7%)

1 SYSTEM 2
0-3/32" = 1 Foot

SYSTEM 2	
Symbol	# OF HEADS
●	520
Total = 520	

SYSTEM #	SYSTEM 9	SYSTEM 8	SYSTEM 7	SYSTEM 6	SYSTEM 5
SYSTEM 1					

KEY PLAN

IMPORTANT
 IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNERS RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
 LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTED LIMITATIONS AND THE MANUFACTURERS INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURERS DATA SHEETS FOR VERIFICATION OF LISTING, LABELS AND MANUFACTURERS INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
 AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
 MONROE, NY 10650
 845-781017
 INFO@GLOBALFIREUSA.COM
 WWW.GLOBALFIREUSA.COM


DISCLAIMER
 THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALLIANCE FIRE PROTECTION INC. (AFCP) GLOBAL FIRE PREVENTION HEREINAFTER KNOWN AS AFCP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. AFCP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, CO-OWNER, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD AFCP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGES, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD AFCP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. AFCP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, CO-OWNER, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
 LIC # 079676

PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
 ROUTE 300
 NEWBURGH, NY

PROJECT LOCATION:
 TAX LOT ID: XXXXX-XXX-XX
 DRAWN BY: AJH
 SCALE: 1/8" = 1'-0" U.N.O.
 DATE: 04/18/2023
FIRE PROTECTION PLAN
 FP-2 3 of 12



Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							

Hydraulic Information	
Remote Area 3	
OCCUPANCY CLASSIFICATION	ESFR
MIN END HEAD PRESSURE	40.000 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2420.25
TOTAL PRESSURE REQUIRED	9057
BASE OF RISER (gpm)	920.25
BASE OF RISER (psi)	115.655
SAFETY MARGIN (psi)	+19.292 (17.4%)

SYSTEM 3	
Symbol	# OF HEADS
●	520
Total = 520	

SYSTEM #	SYSTEM 9	SYSTEM 8	SYSTEM 7	SYSTEM 6	SYSTEM 5
SYSTEM 1					
	SYSTEM 2				
		SYSTEM 3			
			SYSTEM 4		


KEY PLAN

IMPORTANT
 IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
 LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTING LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.


CONTRACTOR
GLOBAL FIRE PREVENTION
 AUTOMATIC FIRE SPRINKLERS

 59 GILBERT STREET, SUITE 101
 MONROE, NY 10950
 845-7810197
 INFO@GLOBALFIREUSA.COM
 WWW.GLOBALFIREUSA.COM

DISCLAIMER
 THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL IN-HOUSE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ACFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ACFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, CO-SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ACFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGES, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ACFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ACFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING, THE OWNER, CO-SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

 MICHAEL E. MELE, PE
 LIC # 079676

PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
 ROUTE 300
 NEWBURGH, NY
 PROJECT LOCATION:
 TAX LOT ID: XXX-XX-XX
 DRAWN BY: AJH
 SCALE: 1/8" = 1'-0" U.N.O.
 DATE: 04/18/2023
FIRE PROTECTION PLAN
 FP-3 4 of 12



Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	25.2	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							

IMPORTANT
 IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.

LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTING, LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
 AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
 MONROE, NY 13060
 845-7810107
 INFO@GLOBALFIREUSA.COM
 WWW.GLOBALFIREUSA.COM

DISCLAIMER
 THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALLIANCE FIRE PROTECTION INC. (AIFP) GLOBAL FIRE PREVENTION HEREINAFTER KNOWN AS AIFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. AIFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, OR SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHICH ACQUIRES OR OBTAINS THIS DRAWING SHALL, TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD AIFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGES, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THE SYSTEM IN ANY EVENT SHOULD AIFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. AIFP INC. TOTAL LIABILITY ARISING OUT OF, OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, OR SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHICH ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
 LIC # 079676

PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
 ROUTE 300
 NEWBURGH, NY

TAX LOT ID: XXX-XX-XX
 DRAWN BY: AJH
 SCALE: 1/8" = 1'-0" U.N.O.
 DATE: 04/18/2023
FIRE PROTECTION PLAN
 FP-4 5 of 12

Hydraulic Information	
Remote Area 4	
OCCUPANCY CLASSIFICATION	ESFR
MIN. END HEAD PRESSURE	40,000 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	25.2
TOTAL WATER REQUIRED	2420.43
TOTAL PRESSURE REQUIRED	9.424
BASE OF RISER (gpm)	9520.43
BASE OF RISER (psi)	157.9
SAFETY MARGIN (psi)	+24.921 (72.6%)


SYSTEM 4	
Symbol	# OF HEADS
●	340
Total = 340	

1 SYSTEM 4
 0-3/32" = 1 Foot

SYSTEM #	SYSTEM 9	SYSTEM 8	SYSTEM 7	SYSTEM 6	SYSTEM 5
SYSTEM 1					
SYSTEM 2					
SYSTEM 3					
SYSTEM 4					

KEY PLAN

Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							



Hydraulic Information	
Remote Area 5	
OCCUPANCY CLASSIFICATION	ESFR - SYSTEM 5
MIN END HEAD PRESSURE	40.00 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2420.65
TOTAL PRESSURE REQUIRED	15.460
BASE of RISER (gpm)	920.05
BASE of RISER (psi)	115.000
SAFETY MARGIN (psi)	+9.891 (85.9%)

1 SYSTEM 5
0-3/32" = 1 Foot

SYSTEM 5	
Symbol	# OF HEADS
●	275
Total = 275	

SYSTEM 1	SYSTEM 2	SYSTEM 3	SYSTEM 4	SYSTEM 5
SYSTEM 1	SYSTEM 2	SYSTEM 3	SYSTEM 4	SYSTEM 5

KEY PLAN

IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNERS RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURERS INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURERS DATA SHEETS FOR VERIFICATION OF LISTINGS, LABELS AND MANUFACTURERS INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

56 GILBERT STREET, SUITE 101
MONROE, NY 10650
845-7810107
INFO@GLOBALFIREUSA.COM
WWW.GLOBALFIREUSA.COM

DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL IN-HOUSE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ADFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, GC, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ADFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, GC, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.


SEAL AND SIGNATURE

MICHAEL E. MIELE, PE
LIC # 079676

PROJECT INFORMATION:
**PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK**
PROJECT LOCATION:
ROUTE 300
NEWBURGH, NY

TAX LOT ID: XXX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" U.N.O.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-5 6 of 12

Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							



Hydraulic Information	
Retrofit Area 6	
OCCUPANCY CLASSIFICATION	ESFR - SYSTEM 6
MIN. END HEAD PRESSURE	40.000 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2422.15
TOTAL PRESSURE REQUIRED	-2.072
BASE OF RISER (psig)	1920.15
BASE OF RISER (psi)	95.478
SAFETY MARGIN (psi)	+38.422 (39.6%)

1 SYSTEM 6
0-3/32" = 1 Foot

SYSTEM 6	
Symbol	# OF HEADS
●	350
Total = 350	

11

12

13

IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTINGS, LABELS, AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
MONROE, NY 10560
845-781-0177
INFO@GLOBALFIREUSA.COM
www.globalfireusa.com

DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL-KONE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ACFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ACFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, CO-OWNER, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL, TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ACFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ACFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ACFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, CO-OWNER, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
LIC # 079676


PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
ROUTE 300
NEWBURGH, NY

SYSTEM #	SYSTEM 1	SYSTEM 2	SYSTEM 3	SYSTEM 4	SYSTEM 5	SYSTEM 6	SYSTEM 7	SYSTEM 8	SYSTEM 9
SYSTEM #									

TAX LOT ID: XXX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" U.N.O.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-6 7 of 12

KEY PLAN


Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							



Hydraulic Information	
Remote Area 7	
OCCUPANCY CLASSIFICATION	ESFR - SYSTEM 7
MIN. END HEAD PRESSURE	40.000 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	52
K-FACTOR	252
TOTAL WATER REQUIRED	249.64
TOTAL PRESSURE REQUIRED	-2.396
BASE OF RISER (gpm)	199.64
BASE OF RISER (psi)	95.93
SAFETY MARGIN (psi)	+36.757 (107.0%)

1 SYSTEM 7
0-3/32" = 1 Foot

SYSTEM 7	
Symbol	# OF HEADS
●	500
Total = 500	



IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.

LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTING, LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
MONROE, NY 10560
845-7810197
INFO@GLOBALFIREUSA.COM
WWW.GLOBALFIREUSA.COM

DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL-KONE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ADFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, GC, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL, TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY RELIANCE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ADFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, GC, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE


MICHAEL E. MELE, PE
LIC # 079676

PROJECT INFORMATION:
PROJECT LOCATION: PROPOSED WAREHOUSE FARRELL INDUSTRIAL PARK ROUTE 300 NEWBURGH, NY

TAX LOT ID: XXX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" U.N.O.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-7 8 of 12

KEY PLAN

Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							




Hydraulic Information	
Remote Area 8	
OCCUPANCY CLASSIFICATION	ESFR - SYSTEM 8
MIN. END HEAD PRESSURE	40.00 (ESFR)
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	252
TOTAL WATER REQUIRED	2420.16
TOTAL PRESSURE REQUIRED	4.291
BASE OF RISER (psf)	500.00
BASE OF RISER (psi)	91.840
SAFETY MARGIN (psi)	+30.000 (37.5%)

Supply Flow Test Data	
Static Pressure	60.000
Residual Pressure	55.000
Flow	1000.000

SYSTEM 8	
Symbol	# OF HEADS
●	500
Total = 500	

1 SYSTEM 8
0-3/32" = 1 Foot



IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.

LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTING, LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

56 GILBERT STREET, SUITE 101
MONROE, NY 10950
845-7810197
INFO@GLOBALFIREUSA.COM
www.globalfireusa.com

DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL-KNOVE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ADFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, GC, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL, TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY RELIANCE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THE SYSTEM IN ANY EVENT SHOULD ADFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING, THE OWNER, GC, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE


MICHAEL E. MELE, PE
LIC # 079676

PROJECT INFORMATION:
PROJECT LOCATION: PROPOSED WAREHOUSE FARRELL INDUSTRIAL PARK ROUTE 300 NEWBURGH, NY

TAX LOT ID: XXX-XXX-XXX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" UNO.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-8 9 of 12


KEY PLAN

Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							



1 SYSTEM 9
0-3/32" = 1 Foot

SYSTEM 9	
Symbol	# OF HEADS
●	350
Total = 350	



KEY PLAN

IMPORTANT
 IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNERS RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
 LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURERS INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURERS DATA SHEETS FOR VERIFICATION OF LISTINGS, LABELS AND MANUFACTURERS INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
 AUTOMATIC FIRE SPRINKLERS

56 GILBERT STREET, SUITE 101
 MONROE, NY 10650
 845-7810197
 INFO@GLOBALFIREUSA.COM
 WWW.GLOBALFIREUSA.COM

DISCLAIMER
 THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL IN-HOUSE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ADFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, CO-OWNER, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ADFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, CO-OWNER, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
 LIC # 079676

PROJECT INFORMATION:
 PROPOSED WAREHOUSE
 FARRELL INDUSTRIAL PARK
 ROUTE 300
 NEWBURGH, NY

TAX LOT ID: XXX-XX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" UNO.
DATE: 04/18/2023
FIRE PROTECTION PLAN
 FP-9 10 of 12


Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	25.2	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							



Hydraulic Information	
Remote Area 10	
OCCUPANCY CLASSIFICATION	ESFR - SYSTEM 10
TOTAL HOSE STREAMS	500.00
TOTAL HEADS FLOWING	12
K-FACTOR	25.2
TOTAL WATER REQUIRED	2400.00
TOTAL PRESSURE REQUIRED	14.54
BASE OF RISER (psig)	120.00
SAFETY MARGIN (psig)	+9.807 (57.7%)

1 SYSTEM 10
0-3/32" = 1 Foot

SYSTEM 10	
Symbol	# OF HEADS
●	275
Total = 275	



KEY PLAN

IMPORTANT
IN LOCATIONS SUBJECT TO FREEZING CONDITIONS, IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.
LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTED LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTINGS, LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR
GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
MONROE, NY 13060
845-7810107
INFO@GLOBALFIREUSA.COM
www.globalfireusa.com

DISCLAIMER
THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALL-KNOVE FIRE PROTECTION INC. (DBA GLOBAL FIRE PREVENTION) HEREINAFTER KNOWN AS ADFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER, CO-OWNER, SUB-CONTRACTOR, OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THE SYSTEM IN ANY EVENT SHOULD ADFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER, CO-OWNER, SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHO ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS AND AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
LIC # 079676

PROJECT INFORMATION:
PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
ROUTE 300
NEWBURGH, NY

TAX LOT ID: XXX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" U.N.O.
DATE: 04/18/2023

FIRE PROTECTION PLAN
FP-10 11 of 12

Sprinkler Legend - Project Total											
Symbol	Manufacturer	SIN	Model	Quantity	K-Factor	Type	Size	Response	Finish	Temperature	Spacing
●	Reliable	RA0912	N25 ESFR	3440	252	Pendent	1	Fast	Brass	212 °F	
				Total = 3440							

STORAGE FOR CEILING HEIGHTS UP TO 45'-0" USING ESFR K25.0 SPRINKLERS:

COMMODITY	CONFIGURATION	RACK STORAGE (A,B)	SOLID PILED / PALLETTIZED
GROUP A PLASTICS NONEXPANDED	CARTONED	40 FT	30 FT
	EXPOSED	25 FT	30 FT
CLASS IV	NON-ENCAPSULATED(D)	40 FT	35 FT
CLASS I - III	NON-ENCAPSULATED(D)	40 FT	35 FT
IDLE WOOD PALLETS	STACKED ON FLOOR	20 FT	25 FT


IMPORTANT: A MINIMUM CLEARANCE OF 36" BETWEEN THE SPRINKLER DEFLECTOR AND THE TOP OF STORAGE MUST BE MAINTAINED

FOOTNOTES:


- (A) Solid Shelf Racks: Will require in-rack sprinklers depending on the cubic feet of the shelf area (See Sec 16.1.6)
- (B) Must comply with Flue Requirements in accordance with NFPA 13
- (D) Pallets of goods are not to be wrapped on the top with plastic sheeting with greater than 50% coverage.

GENERAL RACK STORAGE NOTES:


- 1. Racks are to be Single or Double row open grate racking, with a minimum of 8'-0" aisles between racks.
- 2. No longitudinal flue space required between racks. 6" nominal transverse flue spaces shall be maintained at all rack uprights.
- 3. Column Protection not required per NFPA 13, 16.1.4.1
- 4. Open top containers of all commodities shall not be stored over 12ft.



PUMP ROOM ISOMETRIC
N.T.S.



PUMP ROOM LAYOUT
1/4" = 1 Foot



KEY PLAN

IMPORTANT

IN LOCATIONS SUBJECT TO FREEZING CONDITIONS IT IS THE OWNER'S RESPONSIBILITY TO PROVIDE SUFFICIENT HEAT TO MAINTAIN A MINIMUM OF 40°F THROUGHOUT WET PIPE SPRINKLER SYSTEM AREAS AND ENCLOSURES FOR DRY PIPE, DELUGE AND OTHER TYPES OF VALVES CONTROLLING WATER SUPPLIES TO SPRINKLER SYSTEMS.

LISTED OR LABELED DEVICES AND MATERIALS SHALL BE INSTALLED AND USED IN ACCORDANCE WITH THE LISTING LIMITATIONS AND THE MANUFACTURER'S INSTRUCTIONS UNLESS PERMITTED BY OTHER SECTIONS OF THIS DOCUMENT. SEE MANUFACTURER'S DATA SHEETS FOR VERIFICATION OF LISTINGS, LABELS AND MANUFACTURER'S INSTALLATION INSTRUCTIONS OF EQUIPMENT, MATERIALS, AND APPLIANCES.

CONTRACTOR

GLOBAL FIRE PREVENTION
AUTOMATIC FIRE SPRINKLERS

59 GILBERT STREET, SUITE 101
MONROE, NY 10560
845-781-0107
INFO@GLOBALFIREUSA.COM
WWW.GLOBALFIREUSA.COM

DISCLAIMER

THIS DRAWING REPRESENTS THE DRAFTING WORK PERFORMED BY ALLIANCE FIRE PROTECTION INC. (A/F/PRO) A DIVISION OF ADFFP INC. ONCE THIS DRAWING LEAVES OUR OFFICE, WE HAVE NO CONTROL OVER ANY CHANGES MADE TO THE BLUEPRINTS AND/OR COPIES OF THE ORIGINAL DRAWING. ADFFP INC. IS NOT RESPONSIBLE FOR THE INSTALLATION AND CANNOT BE HELD RESPONSIBLE FOR ANY CLAIMS THAT MAY ARISE FROM THE INSTALLATION OF THIS SYSTEM. THE OWNER OR SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHICH ACQUIRES OR OBTAINS THIS DRAWING SHALL TO THE FULLEST EXTENT PERMITTED BY LAW, INDEMNIFY AND HOLD ADFFP INC. AND ITS OFFICES, EMPLOYEES & SUBSIDIARIES HARMLESS FROM ANY DAMAGE, LIABILITY OR COST, INCLUDING REASONABLE ATTORNEY FEES AND COST OF DEFENSE, ARISING FROM ANY REUSE OR MODIFICATIONS MADE TO THIS DRAWING AND/OR INSTALLATION OF THIS SYSTEM IN ANY EVENT SHOULD ADFFP INC. BE LIABLE FOR ANY LOSS OF INCOME, PROFITS OR ANY DAMAGES. ADFFP INC. TOTAL LIABILITY ARISING OUT OF OR IN ANYWAY CONNECTED WITH THIS DRAWING WILL NOT EXCEED THE TOTAL AMOUNT OF OUR CONTRACT. FURTHERMORE, BY ACCEPTING THIS DRAWING THE OWNER OR SUB-CONTRACTOR OR ANY PERSON OR ENTITY WHICH ACQUIRES OR OBTAINS THIS DRAWING ACCEPTS & AGREES TO THE TERMS OUTLINED HEREIN.

SEAL AND SIGNATURE

MICHAEL E. MELE, PE
LIC # 079676

PROJECT INFORMATION:

PROPOSED WAREHOUSE
FARRELL INDUSTRIAL PARK
ROUTE 300
NEWBURGH, NY

TAX LOT ID: XXX-XX-XX-XX
DRAWN BY: AJH
SCALE: 1/8" = 1'-0" U.N.O.
DATE: 04/18/2023
FIRE PROTECTION PLAN
FP-11 12 of 12



Hydraulic Summary

Job Number: Route 300
Report Description: ESFR (1)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System		Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000		Occupancy ESFR	Job Suffix
Hose Allowance At Source 500.00		Pressure 40.000	Area of Application NA
Additional Hose Supplies Node <u>Flow(gpm)</u>		Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
			Coverage Per Sprinkler 100 ft ²
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area			
Total Hose Streams 500.00			
System Flow Demand 1920.43	Total Water Required (including Hose Allowance) 2420.43		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 19.78 between nodes 27 and 110			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20091.78 gal	Volume capacity of Dry Pipes		

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000 @	1000.00	34.345 @	2420.43	7.447	26.898
17	Pump		120.000	100.000 @	2000.00	132.045 @	1920.43	105.147	26.898


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21	Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention	Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101	FAX	
Address 2 Monroe, NY 10950	E-mail andrew@globalfireusa.com	
Address 3	Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.345 @ 2420.43

Required Pressure at System Demand
7.447 @ 1920.43

Required Pressure at System Demand (Including Hose Allowance at Source)
7.447 @ 2420.43



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.447 @ 1920.43		
Available Pressure at System Demand		
132.045 @ 1920.43		
Required Pressure at System Demand		
105.147 @ 1920.43		



Node Analysis


Job Number: Route 300
Report Description: ESFR (1)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
173	43'-0	PO(16'-5½)	65.186	
174	43'-0	PO(16'-5½)	65.220	
761	2'-6	fE(15'-3), BOR	105.042	
20	-4'-0	S	7.447	1920.43
110	45'-0	Spr(-40.785)	40.785	160.93
111	45'-0	Spr(-40.571)	40.571	160.51
6909	45'-0	Spr(-40.683)	40.683	160.73
6910	45'-0	Spr(-40.705)	40.705	160.78
6979	45'-0	Spr(-40.008)	40.008	159.39
6980	45'-0	Spr(-40.029)	40.029	159.44
6981	45'-0	Spr(-40.107)	40.107	159.59
7050	45'-0	Spr(-40.000)	40.000	159.38
7051	45'-0	Spr(-40.022)	40.022	159.42
7052	45'-0	Spr(-40.100)	40.100	159.58
7121	45'-0	Spr(-40.471)	40.471	160.31
7122	45'-0	Spr(-40.492)	40.492	160.36
17	2'-6	P2(-101.447)	105.147	
18	2'-6	P1	3.700	
19	-4'-0	E(26'-0)	7.031	
25	43'-0	PO(16'-5½)	65.128	
26	43'-0	PO(16'-5½)	65.165	
27	43'-0	PO(16'-5½)	65.296	
28	43'-0	PO(16'-5½)	65.574	
29	43'-0	PO(16'-5½)	65.866	
30	43'-0	PO(16'-5½)	66.171	
31	43'-0	PO(16'-5½)	66.504	
32	43'-0	PO(16'-5½)	66.868	
33	43'-0	PO(16'-5½)	67.265	
34	43'-0	PO(16'-5½)	67.699	
35	43'-0	T(37'-8½)	69.958	
37	43'-0	PO(16'-5½)	63.506	
38	43'-0	PO(16'-5½)	63.537	
39	43'-0	PO(16'-5½)	63.646	
40	43'-0	PO(16'-5½)	63.878	
41	43'-0	PO(16'-5½)	64.078	
42	43'-0	PO(16'-5½)	64.249	
43	43'-0	PO(16'-5½)	64.400	
44	43'-0	PO(16'-5½)	64.530	
45	43'-0	PO(16'-5½)	64.641	
104	43'-0	PO(16'-5½)	69.505	
105	43'-0	PO(16'-5½)	69.507	
106	43'-0	PO(16'-5½)	69.517	
107	43'-0	PO(16'-5½)	69.537	
108	43'-0	PO(16'-5½)	69.572	
109	43'-0	PO(16'-5½)	69.623	
148	43'-0	PO(16'-5½)	64.732	
149	43'-0	PO(16'-5½)	65.134	
170	43'-0	PO(16'-5½)	65.240	
171	43'-0	PO(37'-8½)	65.291	
172	43'-0	PO(37'-8½)	65.316	




Hydraulic Summary

Job Number: Route 300
Report Description: ESFR (2)

Job													
Job Number Route 300			Design Engineer A.Hergenreder										
Job Name: Farrell Industrial Park			State Certification/License Number										
Address 1 Route 300			AHJ										
Address 2 Newburgh, NY			Job Site/Building										
Address 3			Drawing Name FP_Rte300_Farrell_Indust_Park.cad										
System					Remote Area(s)								
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000			Occupancy ESFR			Job Suffix							
Hose Allowance At Source 500.00			Pressure 40.000			Area of Application NA							
Additional Hose Supplies Node Flow(gpm)			Number Of Sprinklers Calculated 12		Number Of Nozzles Calculated 0		Coverage Per Sprinkler 100 ft²						
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area													
Total Hose Streams 500.00													
System Flow Demand 1920.25		Total Water Required (Including Hose Allowance) 2420.25											
Maximum Pressure Unbalance In Loops 0.000													
Maximum Velocity Above Ground 19.41 between nodes 1152 and 98													
Maximum Velocity Under Ground 7.25 between nodes 20 and 19													
Volume capacity of Wet Pipes 20091.78 gal		Volume capacity of Dry Pipes											
Supplies													
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)				
20	Water Supply	500.00	60.000	55.000 @	1000.00	34.349 @	2420.25	17.621	16.727				
17	Pump		120.000	100.000 @	2000.00	132.052 @	1920.25	115.325	16.727				
Pumps: Static = Churn (Pressure @ Zero Flow)													
Contractor													
Contractor Number 21			Contact Name Andrew Hergenreder				Contact Title Plans Department						
Name of Contractor: Global Fire Prevention			Phone 845-781-0117				Extension 110						
Address 1 59 Gilbert Street, Suite 101			FAX										
Address 2 Monroe, NY 10950			E-mail andrew@globalfireusa.com										
Address 3			Web-Site www.globalfireusa.com										



Water Supply at Node 20



Hydraulic Graph

Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.349 @ 2420.25

Required Pressure at System Demand
17.621 @ 1920.25

Required Pressure at System Demand (Including Hose Allowance at Source)
17.621 @ 2420.25



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.450 @ 1920.25		
Available Pressure at System Demand		
132.052 @ 1920.25		
Required Pressure at System Demand		
115.325 @ 1920.25		



Node Analysis

Job Number: Route 300
Report Description: ESFR (2)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	17.621	1920.25
300	45'-0	Spr(-40.000)	40.000	159.38
301	45'-0	Spr(-40.002)	40.002	159.38
302	45'-0	Spr(-40.624)	40.624	160.62
303	45'-0	Spr(-40.517)	40.517	160.41
304	45'-0	Spr(-40.020)	40.020	159.42
305	45'-0	Spr(-40.022)	40.022	159.42
306	45'-0	Spr(-40.645)	40.645	160.66
307	45'-0	Spr(-40.537)	40.537	160.45
308	45'-0	Spr(-40.092)	40.092	159.56
309	45'-0	Spr(-40.094)	40.094	159.57
310	45'-0	Spr(-40.718)	40.718	160.80
311	45'-0	Spr(-40.610)	40.610	160.59
17	2'-6	P2(-101.450)	115.325	
18	2'-6	P1	13.875	
19	-4'-0	E(26'-0)	17.205	
75	43'-0	PO(16'-5½)	64.082	
76	43'-0	PO(16'-5½)	64.114	
77	43'-0	PO(16'-5½)	64.229	
78	43'-0	PO(16'-5½)	64.474	
79	43'-0	PO(16'-5½)	64.722	
80	43'-0	PO(16'-5½)	64.975	
81	43'-0	PO(16'-5½)	65.235	
82	43'-0	PO(16'-5½)	65.501	
83	43'-0	PO(16'-5½)	65.776	
84	43'-0	PO(16'-5½)	66.061	
85	43'-0	PO(16'-5½)	66.358	
86	43'-0	PO(16'-5½)	66.669	
87	43'-0	PO(16'-5½)	66.996	
88	43'-0	PO(16'-5½)	67.341	
89	43'-0	PO(16'-5½)	67.708	
90	43'-0	PO(16'-5½)	68.100	
91	43'-0	PO(16'-5½)	68.519	
92	43'-0	PO(16'-5½)	68.971	
93	43'-0	PO(16'-5½)	69.460	
94	43'-0	PO(16'-5½)	69.990	
95	43'-0	PO(16'-5½)	70.568	
96	43'-0	PO(16'-5½)	71.199	
97	43'-0	PO(16'-5½)	71.892	
98	43'-0	PO(16'-5½)	72.652	
100	43'-0	PO(16'-5½)	64.054	
101	43'-0	PO(16'-5½)	64.083	
102	43'-0	PO(16'-5½)	64.189	
103	43'-0	PO(16'-5½)	64.411	
116	43'-0	PO(16'-5½)	66.882	
117	43'-0	PO(16'-5½)	66.894	
118	43'-0	PO(37'-8½)	66.913	
119	43'-0	PO(16'-5½)	66.821	
120	43'-0	PO(16'-5½)	66.858	
121	43'-0	PO(16'-5½)	66.703	
122	43'-0	PO(16'-5½)	66.770	
123	43'-0	PO(16'-5½)	66.521	
124	43'-0	PO(16'-5½)	66.620	
125	43'-0	PO(16'-5½)	66.279	
126	43'-0	PO(16'-5½)	66.408	
127	43'-0	PO(16'-5½)	65.982	
128	43'-0	PO(16'-5½)	66.137	
129	43'-0	PO(16'-5½)	65.639	
130	43'-0	PO(16'-5½)	65.816	
131	43'-0	PO(16'-5½)	65.257	
132	43'-0	PO(16'-5½)	65.452	
133	43'-0	PO(16'-5½)	64.845	



Node Analysis

Job Number: Route 300
Report Description: ESFR (2)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
134	43'-0	PO(16'-5½)	65.054	
135	43'-0	PO(16'-5½)	64.630	
761	2'-6	fE(15'-3), BOR	115.220	
1152	43'-0	E(17'-7)	90.498	




Hydraulic Summary

Job Number: Route 300
Report Description: ESFR (3)

Job									
Job Number Route 300					Design Engineer A.Hergenreder				
Job Name: Farrell Industrial Park					State Certification/License Number				
Address 1 Route 300					AHJ				
Address 2 Newburgh, NY					Job Site/Building				
Address 3					Drawing Name FP_Rte300_Farrell_Indust_Park.cad				
System					Remote Area(s)				
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000					Occupancy ESFR			Job Suffix	
Hose Allowance At Source 500.00					Pressure 40.000			Area of Application NA	
Additional Hose Supplies Node Flow(gpm)					Number Of Sprinklers Calculated 12		Number Of Nozzles Calculated 0	Coverage Per Sprinkler 100 ft²	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area									
Total Hose Streams 500.00									
System Flow Demand 1920.25			Total Water Required (Including Hose Allowance) 2420.25						
Maximum Pressure Unbalance In Loops 0.000									
Maximum Velocity Above Ground 19.41 between nodes 1150 and 69									
Maximum Velocity Under Ground 7.25 between nodes 20 and 19									
Volume capacity of Wet Pipes 20091.78 gal			Volume capacity of Dry Pipes						
Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000 @	1000.00	34.349 @	2420.25	18.057	16.292
17	Pump		120.000	100.000 @	2000.00	132.052 @	1920.25	115.760	16.292
Pumps: Static = Churn (Pressure @ Zero Flow)									
Contractor									
Contractor Number 21					Contact Name Andrew Hergenreder			Contact Title Plans Department	
Name of Contractor: Global Fire Prevention					Phone 845-781-0117			Extension 110	
Address 1 59 Gilbert Street, Suite 101					FAX				
Address 2 Monroe, NY 10950					E-mail andrew@globalfireusa.com				
Address 3					Web-Site www.globalfireusa.com				



Water Supply at Node 20



Hydraulic Graph

Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.349 @ 2420.25

Required Pressure at System Demand
18.057 @ 1920.25

Required Pressure at System Demand (Including Hose Allowance at Source)
18.057 @ 2420.25



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.450 @ 1920.25		
Available Pressure at System Demand		
132.052 @ 1920.25		
Required Pressure at System Demand		
115.760 @ 1920.25		



Node Analysis

Job Number: Route 300
Report Description: ESFR (3)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	18.057	1920.25
500	45'-0	Spr(-40.000)	40.000	159.38
501	45'-0	Spr(-40.002)	40.002	159.38
502	45'-0	Spr(-40.624)	40.624	160.62
503	45'-0	Spr(-40.517)	40.517	160.41
504	45'-0	Spr(-40.020)	40.020	159.42
505	45'-0	Spr(-40.022)	40.022	159.42
506	45'-0	Spr(-40.645)	40.645	160.66
507	45'-0	Spr(-40.537)	40.537	160.45
508	45'-0	Spr(-40.092)	40.092	159.56
509	45'-0	Spr(-40.094)	40.094	159.57
510	45'-0	Spr(-40.718)	40.718	160.80
511	45'-0	Spr(-40.610)	40.610	160.59
17	2'-6	P2(-101.450)	115.760	
18	2'-6	P1	14.310	
19	-4'-0	E(26'-0)	17.641	
46	43'-0	PO(16'-5½)	64.082	
47	43'-0	PO(16'-5½)	64.114	
48	43'-0	PO(16'-5½)	64.229	
49	43'-0	PO(16'-5½)	64.474	
50	43'-0	PO(16'-5½)	64.722	
51	43'-0	PO(16'-5½)	64.975	
52	43'-0	PO(16'-5½)	65.235	
53	43'-0	PO(16'-5½)	65.501	
54	43'-0	PO(16'-5½)	65.776	
55	43'-0	PO(16'-5½)	66.061	
56	43'-0	PO(16'-5½)	66.358	
57	43'-0	PO(16'-5½)	66.669	
58	43'-0	PO(16'-5½)	66.996	
59	43'-0	PO(16'-5½)	67.341	
60	43'-0	PO(16'-5½)	67.708	
61	43'-0	PO(16'-5½)	68.100	
62	43'-0	PO(16'-5½)	68.519	
63	43'-0	PO(16'-5½)	68.971	
64	43'-0	PO(16'-5½)	69.460	
65	43'-0	PO(16'-5½)	69.990	
66	43'-0	PO(16'-5½)	70.568	
67	43'-0	PO(16'-5½)	71.199	
68	43'-0	PO(16'-5½)	71.892	
69	43'-0	PO(16'-5½)	72.652	
71	43'-0	PO(16'-5½)	64.054	
72	43'-0	PO(16'-5½)	64.083	
73	43'-0	PO(16'-5½)	64.189	
74	43'-0	PO(16'-5½)	64.411	
150	43'-0	PO(16'-5½)	64.630	
151	43'-0	PO(16'-5½)	64.845	
152	43'-0	PO(16'-5½)	65.054	
153	43'-0	PO(16'-5½)	65.257	
154	43'-0	PO(16'-5½)	65.452	
155	43'-0	PO(16'-5½)	65.639	
156	43'-0	PO(16'-5½)	65.816	
157	43'-0	PO(16'-5½)	65.982	
158	43'-0	PO(16'-5½)	66.137	
159	43'-0	PO(16'-5½)	66.279	
160	43'-0	PO(16'-5½)	66.408	
161	43'-0	PO(16'-5½)	66.521	
162	43'-0	PO(16'-5½)	66.620	
163	43'-0	PO(16'-5½)	66.703	
164	43'-0	PO(16'-5½)	66.770	
165	43'-0	PO(16'-5½)	66.821	
166	43'-0	PO(16'-5½)	66.858	
167	43'-0	PO(16'-5½)	66.882	



Node Analysis


Job Number: Route 300
Report Description: ESFR (3)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
168	43'-0	PO(16'-5½)	66.894	
169	43'-0	PO(37'-8½)	66.913	
761	2'-6	fE(15'-3), BOR	115.655	
1150	43'-0	E(17'-7)	90.592	



Hydraulic Summary

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System		Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000		Occupancy ESFR	Job Suffix
Hose Allowance At Source 500.00		Pressure 40.000	Area of Application NA
Additional Hose Supplies		Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
<u>Node</u> <u>Flow(gpm)</u>		Coverage Per Sprinkler 100 ft²	
		AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area	
Total Hose Streams 500.00			
System Flow Demand 1920.43	Total Water Required (Including Hose Allowance) 2420.43		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 19.78 between nodes 3 and 710			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20091.78 gal	Volume capacity of Dry Pipes		

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000 @	1000.00	34.345 @	2420.43	9.424	24.921
17	Pump		120.000	100.000 @	2000.00	132.045 @	1920.43	107.125	24.921


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21		Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention		Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101		FAX	
Address 2 Monroe, NY 10950		E-mail andrew@globalfireusa.com	
Address 3		Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.345 @ 2420.43

Required Pressure at System Demand
9.424 @ 1920.43

Required Pressure at System Demand (Including Hose Allowance at Source)
9.424 @ 2420.43



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.447 @ 1920.43		
Available Pressure at System Demand		
132.045 @ 1920.43		
Required Pressure at System Demand		
107.125 @ 1920.43		



Node Analysis

Job Number: Route 300
Report Description: ESFR (4)


Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	9.424	1920.43
700	45'-0	Spr(-40.000)	40.000	159.38
701	45'-0	Spr(-40.008)	40.008	159.39
702	45'-0	Spr(-40.683)	40.683	160.73
703	45'-0	Spr(-40.470)	40.470	160.31
704	45'-0	Spr(-40.022)	40.022	159.42
705	45'-0	Spr(-40.029)	40.029	159.44
706	45'-0	Spr(-40.705)	40.705	160.78
707	45'-0	Spr(-40.492)	40.492	160.36
708	45'-0	Spr(-40.100)	40.100	159.58
709	45'-0	Spr(-40.108)	40.108	159.59
710	45'-0	Spr(-40.785)	40.785	160.94
711	45'-0	Spr(-40.571)	40.571	160.51
1	43'-0	PO(16'-5½)	65.136	
2	43'-0	PO(16'-5½)	65.172	
3	43'-0	PO(16'-5½)	65.303	
4	43'-0	PO(16'-5½)	65.582	
5	43'-0	PO(16'-5½)	65.874	
6	43'-0	PO(16'-5½)	66.179	
7	43'-0	PO(16'-5½)	66.512	
8	43'-0	PO(16'-5½)	66.875	
9	43'-0	PO(16'-5½)	67.273	
10	43'-0	PO(16'-5½)	67.707	
11	43'-0	T(37'-8½)	69.967	
17	2'-6	P2(-101.447)	107.125	
18	2'-6	P1	5.678	
19	-4'-0	E(26'-0)	9.009	
21	43'-0	PO(16'-5½)	63.515	
22	43'-0	PO(16'-5½)	63.546	
23	43'-0	PO(16'-5½)	63.655	
24	43'-0	PO(16'-5½)	63.887	
112	43'-0	PO(16'-5½)	69.546	
113	43'-0	PO(16'-5½)	69.525	
114	43'-0	PO(16'-5½)	69.516	
115	43'-0	PO(16'-5½)	69.513	
136	43'-0	PO(16'-5½)	64.087	
137	43'-0	PO(16'-5½)	64.258	
138	43'-0	PO(16'-5½)	64.409	
139	43'-0	PO(16'-5½)	64.539	
140	43'-0	PO(16'-5½)	64.650	
141	43'-0	PO(16'-5½)	64.741	
142	43'-0	PO(16'-5½)	65.143	
143	43'-0	PO(16'-5½)	65.195	
144	43'-0	PO(16'-5½)	65.229	
145	43'-0	PO(16'-5½)	65.249	
146	43'-0	PO(37'-8½)	65.300	
147	43'-0	PO(37'-8½)	65.325	
761	2'-6	fE(15'-3), BOR	107.019	
2806	43'-0	PO(16'-5½)	69.580	
2808	43'-0	PO(16'-5½)	69.631	



Hydraulic Summary

Job Number: Route 300
Report Description: ESRF - SYSTEM 5 (5)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System		Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000		Occupancy ESFR - SYSTEM 5	Job Suffix
Hose Allowance At Source 500.00		Pressure 40.000	Area of Application NA
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>		Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
		Coverage Per Sprinkler 100 ft ²	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area			
Total Hose Streams 500.00			
System Flow Demand 1920.65	Total Water Required (Including Hose Allowance) 2420.65		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 20.53 between nodes 340 and 910			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20091.78 gal	Volume capacity of Dry Pipes		

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.341	2420.65	16.406	17.934
17	Pump		120.000	100.000	2000.00	132.037	1920.65	114.103	17.934


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21	Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention	Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101	FAX	
Address 2 Monroe, NY 10950	E-mail andrew@globalfireusa.com	
Address 3	Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.341 @ 2420.65

Required Pressure at System Demand
16.406 @ 1920.65

Required Pressure at System Demand (Including Hose Allowance at Source)
16.406 @ 2420.65



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual Pressure		
101.443 @ 1920.65		
Available Pressure at System Demand		
132.037 @ 1920.65		
Required Pressure at System Demand		
114.103 @ 1920.65		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 5 (5)


Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	16.406	1920.65
900	45'-0	Spr(-40.000)	40.000	159.38
901	45'-0	Spr(-40.023)	40.023	159.42
902	45'-0	Spr(-40.791)	40.791	160.95
903	45'-0	Spr(-40.397)	40.397	160.17
904	45'-0	Spr(-40.020)	40.020	159.42
905	45'-0	Spr(-40.043)	40.043	159.46
906	45'-0	Spr(-40.811)	40.811	160.99
907	45'-0	Spr(-40.418)	40.418	160.21
908	45'-0	Spr(-40.092)	40.092	159.56
909	45'-0	Spr(-40.116)	40.116	159.61
910	45'-0	Spr(-40.886)	40.886	161.13
911	45'-0	Spr(-40.490)	40.490	160.35
17	2'-6	P2(-101.443)	114.103	
18	2'-6	P1	12.659	
19	-4'-0	E(26'-0)	15.990	
338	43'-0	PO(16'-5½)	73.975	
339	43'-0	PO(16'-5½)	74.014	
340	43'-0	PO(16'-5½)	74.154	
341	43'-0	PO(16'-5½)	74.453	
342	43'-0	PO(16'-5½)	74.801	
343	43'-0	PO(16'-5½)	75.199	
344	43'-0	PO(16'-5½)	75.670	
345	43'-0	PO(16'-5½)	76.220	
346	43'-0	PO(16'-5½)	76.857	
347	43'-0	PO(16'-5½)	77.590	
349	43'-0	PO(16'-5½)	64.507	
350	43'-0	PO(16'-5½)	64.536	
351	43'-0	PO(16'-5½)	64.637	
352	43'-0	PO(16'-5½)	64.851	
353	43'-0	PO(16'-5½)	65.118	
354	43'-0	PO(16'-5½)	65.193	
355	43'-0	PO(37'-8½)	65.294	
356	43'-0	PO(16'-5½)	65.008	
357	43'-0	PO(16'-5½)	65.238	
358	43'-0	PO(16'-5½)	65.260	
654	43'-0	E(17'-7)	82.166	
761	2'-6	fE(15'-3), BOR	113.997	



Hydraulic Summary

Job Number: Route 300
Report Description: ESFR - SYSTEM 6 (6)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System	Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000	Occupancy ESFR - SYSTEM 6	Job Suffix
Hose Allowance At Source 500.00	Pressure 40.000	Area of Application NA
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>	Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
	Coverage Per Sprinkler 100 ft²	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area		
		
Total Hose Streams 500.00		
System Flow Demand 1920.32	Total Water Required (Including Hose Allowance) 2420.32	
Maximum Pressure Unbalance In Loops 0.000		
Maximum Velocity Above Ground 19.88 between nodes 265 and 1110		
Maximum Velocity Under Ground 7.25 between nodes 20 and 19		
Volume capacity of Wet Pipes 20084.36 gal	Volume capacity of Dry Pipes	

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.347	2420.32	12.723	21.624
17	Pump		120.000	100.000	2000.00	132.049	1920.32	110.426	21.624


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21		Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention		Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101		FAX	
Address 2 Monroe, NY 10950		E-mail andrew@globalfireusa.com	
Address 3		Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.347 @ 2420.32

Required Pressure at System Demand
12.723 @ 1920.32

Required Pressure at System Demand (Including Hose Allowance at Source)
12.723 @ 2420.32



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static Pressure	177.182	Fire Pump Churn Pressure
177.182	120.000	
Residual Pressure		
101.449 @ 1920.32		
Available Pressure at System Demand		
132.049 @ 1920.32		
Required Pressure at System Demand		
110.426 @ 1920.32		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 6 (6)


Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	12.723	1920.32
1100	45'-0	Spr(-40.000)	40.000	159.38
1101	45'-0	Spr(-40.009)	40.009	159.40
1102	45'-0	Spr(-40.698)	40.698	160.76
1103	45'-0	Spr(-40.459)	40.459	160.29
1104	45'-0	Spr(-40.018)	40.018	159.42
1105	45'-0	Spr(-40.028)	40.028	159.43
1106	45'-0	Spr(-40.717)	40.717	160.80
1107	45'-0	Spr(-40.478)	40.478	160.33
1108	45'-0	Spr(-40.085)	40.085	159.55
1109	45'-0	Spr(-40.095)	40.095	159.57
1110	45'-0	Spr(-40.785)	40.785	160.93
1111	45'-0	Spr(-40.545)	40.545	160.46
17	2'-6	P2(-101.449)	110.426	
18	2'-6	P1	8.977	
19	-4'-0	E(26'-0)	12.308	
261	43'-0	PO(16'-5½)	66.840	
262	43'-0	PO(16'-5½)	73.101	
263	43'-0	PO(16'-5½)	72.036	
264	43'-0	PO(16'-5½)	72.069	
265	43'-0	PO(16'-5½)	72.191	
266	43'-0	PO(16'-5½)	72.449	
267	43'-0	PO(16'-5½)	72.751	
268	43'-0	PO(16'-5½)	73.503	
269	43'-0	PO(16'-5½)	73.962	
270	43'-0	PO(16'-5½)	74.484	
271	43'-0	PO(16'-5½)	75.073	
272	43'-0	PO(16'-5½)	75.738	
273	43'-0	PO(16'-5½)	76.485	
277	43'-0	PO(16'-5½)	66.190	
278	43'-0	PO(16'-5½)	66.218	
279	43'-0	PO(16'-5½)	66.317	
280	43'-0	PO(16'-5½)	66.528	
281	43'-0	PO(16'-5½)	66.701	
282	43'-0	PO(16'-5½)	66.948	
329	43'-0	PO(37'-8½)	67.158	
333	43'-0	PO(16'-5½)	67.116	
334	43'-0	PO(16'-5½)	67.132	
335	43'-0	PO(16'-5½)	67.027	
336	43'-0	PO(16'-5½)	67.082	
641	43'-0	E(17'-7)	80.967	
761	2'-6	fE(15'-3), BOR	110.321	



Hydraulic Summary

Job Number: Route 300
Report Description: ESRF - SYSTEM 7 (7)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System	Remote Area(s)		
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000	Occupancy ESFR - SYSTEM 7	Job Suffix	
Hose Allowance At Source 500.00	Pressure 40.000	Area of Application NA	
Additional Hose Supplies Node Flow(gpm)	Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0	Coverage Per Sprinkler 100 ft²
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area			
			
Total Hose Streams 500.00			
System Flow Demand 1920.16	Total Water Required (Including Hose Allowance) 2420.16		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 19.41 between nodes 596 and 384			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20084.36 gal	Volume capacity of Dry Pipes		

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.350	2420.16	10.510	23.840
17	Pump		120.000	100.000	2000.00	132.056	1920.16	108.215	23.840


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21	Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention	Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101	FAX	
Address 2 Monroe, NY 10950	E-mail andrew@globalfireusa.com	
Address 3	Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.350 @ 2420.16

Required Pressure at System Demand
10.510 @ 1920.16

Required Pressure at System Demand (Including Hose Allowance at Source)
10.510 @ 2420.16



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.452 @ 1920.16		
Available Pressure at System Demand		
132.056 @ 1920.16		
Required Pressure at System Demand		
108.215 @ 1920.16		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 7 (7)


Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	10.510	1920.16
1300	45'-0	Spr(-40.019)	40.019	159.42
1301	45'-0	Spr(-40.019)	40.019	159.42
1302	45'-0	Spr(-40.559)	40.559	160.49
1303	45'-0	Spr(-40.617)	40.617	160.60
1304	45'-0	Spr(-40.001)	40.001	159.38
1305	45'-0	Spr(-40.000)	40.000	159.38
1306	45'-0	Spr(-40.540)	40.540	160.45
1307	45'-0	Spr(-40.598)	40.598	160.57
1308	45'-0	Spr(-40.086)	40.086	159.55
1309	45'-0	Spr(-40.685)	40.685	160.74
1310	45'-0	Spr(-40.085)	40.085	159.55
1311	45'-0	Spr(-40.626)	40.626	160.62
17	2'-6	P2(-101.452)	108.215	
18	2'-6	P1	6.763	
19	-4'-0	E(26'-0)	10.094	
384	43'-0	PO(16'-5½)	76.606	
386	43'-0	PO(16'-5½)	75.842	
388	43'-0	PO(16'-5½)	75.147	
390	43'-0	PO(16'-5½)	74.512	
392	43'-0	PO(16'-5½)	73.932	
394	43'-0	PO(16'-5½)	73.401	
396	43'-0	PO(16'-5½)	72.913	
398	43'-0	PO(16'-5½)	72.465	
400	43'-0	PO(16'-5½)	72.051	
402	43'-0	PO(16'-5½)	71.670	
404	43'-0	PO(16'-5½)	71.317	
406	43'-0	PO(16'-5½)	70.991	
408	43'-0	PO(16'-5½)	70.688	
410	43'-0	PO(16'-5½)	70.408	
412	43'-0	PO(16'-5½)	70.149	
414	43'-0	PO(16'-5½)	69.910	
416	43'-0	PO(16'-5½)	69.796	
418	43'-0	PO(16'-5½)	69.765	
596	43'-0	E(17'-7)	83.428	
761	2'-6	fE(15'-3), BOR	108.110	
2670	43'-0	PO(37'-8½)	70.054	
2672	43'-0	PO(16'-5½)	70.036	
2674	43'-0	PO(16'-5½)	70.025	
2676	43'-0	PO(16'-5½)	70.002	
2678	43'-0	PO(16'-5½)	69.966	
2680	43'-0	PO(16'-5½)	69.915	
2682	43'-0	PO(16'-5½)	69.847	
2684	43'-0	PO(16'-5½)	69.763	
2686	43'-0	PO(16'-5½)	69.661	
2688	43'-0	PO(16'-5½)	69.541	
2690	43'-0	PO(16'-5½)	69.404	
2692	43'-0	PO(16'-5½)	69.249	
2694	43'-0	PO(16'-5½)	69.076	
2696	43'-0	PO(16'-5½)	68.885	
2698	43'-0	PO(16'-5½)	68.676	
2700	43'-0	PO(16'-5½)	68.449	
2702	43'-0	PO(16'-5½)	68.341	
2704	43'-0	PO(16'-5½)	68.311	



Hydraulic Summary

Job Number: Route 300
 Report Description: ESFR - SYSTEM 8 (8)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System	Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000	Occupancy ESFR - SYSTEM 8	Job Suffix
Hose Allowance At Source 500.00	Pressure 40.000	Area of Application NA
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>	Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
	Coverage Per Sprinkler 100 ft ²	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area		
		
Total Hose Streams 500.00		
System Flow Demand 1920.16	Total Water Required (Including Hose Allowance) 2420.16	
Maximum Pressure Unbalance In Loops 0.000		
Maximum Velocity Above Ground 19.08 between nodes 185 and 1910		
Maximum Velocity Under Ground 7.25 between nodes 20 and 19		
Volume capacity of Wet Pipes 20084.36 gal	Volume capacity of Dry Pipes	

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.350	2420.16	6.854	27.497
17	Pump		120.000	100.000	2000.00	132.056	1920.16	104.559	27.497


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21	Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention	Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101	FAX	
Address 2 Monroe, NY 10950	E-mail andrew@globalfireusa.com	
Address 3	Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static Pressure
60.000

Residual Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.350 @ 2420.16

Required Pressure at System Demand
6.854 @ 1920.16

Required Pressure at System Demand (Including Hose Allowance at Source)
6.854 @ 2420.16



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.452 @ 1920.16		
Available Pressure at System Demand		
132.056 @ 1920.16		
Required Pressure at System Demand		
104.559 @ 1920.16		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 8 (8)


Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	6.854	1920.16
1900	45'-0	Spr(-40.000)	40.000	159.38
1901	45'-0	Spr(-40.001)	40.001	159.38
1902	45'-0	Spr(-40.595)	40.595	160.56
1903	45'-0	Spr(-40.543)	40.543	160.46
1904	45'-0	Spr(-40.019)	40.019	159.42
1905	45'-0	Spr(-40.019)	40.019	159.42
1906	45'-0	Spr(-40.614)	40.614	160.60
1907	45'-0	Spr(-40.562)	40.562	160.49
1908	45'-0	Spr(-40.085)	40.085	159.55
1909	45'-0	Spr(-40.086)	40.086	159.55
1910	45'-0	Spr(-40.682)	40.682	160.73
1911	45'-0	Spr(-40.629)	40.629	160.63
17	2'-6	P2(-101.452)	104.559	
18	2'-6	P1	3.107	
19	-4'-0	E(26'-0)	6.438	
181	43'-0	PO(16'-5½)	69.771	
183	43'-0	PO(16'-5½)	69.802	
185	43'-0	PO(16'-5½)	69.915	
187	43'-0	PO(16'-5½)	70.154	
189	43'-0	PO(16'-5½)	70.412	
191	43'-0	PO(16'-5½)	70.690	
193	43'-0	PO(16'-5½)	70.991	
195	43'-0	PO(16'-5½)	71.314	
197	43'-0	PO(16'-5½)	71.663	
199	43'-0	PO(16'-5½)	72.040	
201	43'-0	PO(16'-5½)	72.448	
203	43'-0	PO(16'-5½)	72.890	
205	43'-0	PO(16'-5½)	73.371	
207	43'-0	PO(16'-5½)	73.894	
209	43'-0	PO(16'-5½)	74.464	
211	43'-0	PO(16'-5½)	75.087	
214	43'-0	PO(16'-5½)	75.770	
216	43'-0	T(37'-8½)	79.206	
242	43'-0	PO(16'-5½)	68.380	
243	43'-0	PO(16'-5½)	68.410	
244	43'-0	PO(16'-5½)	68.518	
245	43'-0	PO(16'-5½)	68.746	
246	43'-0	PO(16'-5½)	79.183	
247	43'-0	PO(16'-5½)	68.956	
248	43'-0	PO(16'-5½)	69.148	
249	43'-0	PO(16'-5½)	69.323	
250	43'-0	PO(16'-5½)	69.480	
251	43'-0	PO(16'-5½)	69.620	
252	43'-0	PO(16'-5½)	69.742	
253	43'-0	PO(16'-5½)	69.846	
254	43'-0	PO(16'-5½)	69.934	
255	43'-0	PO(16'-5½)	70.004	
256	43'-0	PO(16'-5½)	70.058	
257	43'-0	PO(16'-5½)	70.097	
258	43'-0	PO(16'-5½)	70.122	
259	43'-0	PO(16'-5½)	70.136	
260	43'-0	PO(37'-8½)	70.161	
761	2'-6	fE(15'-3), BOR	104.454	



Hydraulic Summary

Job Number: Route 300
Report Description: ESRF - SYSTEM 9 (9)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad


System	Remote Area(s)		
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000	Occupancy ESFR - SYSTEM 9	Job Suffix	
Hose Allowance At Source 500.00	Pressure 40.000	Area of Application NA	
Additional Hose Supplies <u>Node</u> <u>Flow(gpm)</u>	Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0	Coverage Per Sprinkler 100 ft ²
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area			
			
Total Hose Streams 500.00			
System Flow Demand 1920.32	Total Water Required (Including Hose Allowance) 2420.32		
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 19.88 between nodes 215 and 1510			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20084.36 gal	Volume capacity of Dry Pipes		

Supplies									
Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.347	2420.32	12.756	21.591
17	Pump		120.000	100.000	2000.00	132.049	1920.32	110.458	21.591
Pumps: Static = Churn (Pressure @ Zero Flow)									

Contractor			
Contractor Number 21		Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention		Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101		FAX	
Address 2 Monroe, NY 10950		E-mail andrew@globalfireusa.com	
Address 3		Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph

Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.347 @ 2420.32

Required Pressure at System Demand
12.756 @ 1920.32

Required Pressure at System Demand (Including Hose Allowance at Source)
12.756 @ 2420.32



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual Pressure		
101.449 @ 1920.32		
Available Pressure at System Demand		
132.049 @ 1920.32		
Required Pressure at System Demand		
110.458 @ 1920.32		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 9 (9)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	12.756	1920.32
1500	45'-0	Spr(-40.000)	40.000	159.38
1501	45'-0	Spr(-40.009)	40.009	159.40
1502	45'-0	Spr(-40.698)	40.698	160.76
1503	45'-0	Spr(-40.459)	40.459	160.29
1504	45'-0	Spr(-40.018)	40.018	159.42
1505	45'-0	Spr(-40.028)	40.028	159.43
1506	45'-0	Spr(-40.717)	40.717	160.80
1507	45'-0	Spr(-40.478)	40.478	160.33
1508	45'-0	Spr(-40.085)	40.085	159.55
1509	45'-0	Spr(-40.095)	40.095	159.57
1510	45'-0	Spr(-40.785)	40.785	160.93
1511	45'-0	Spr(-40.545)	40.545	160.46
17	2'-6	P2(-101.449)	110.458	
18	2'-6	P1	9.009	
19	-4'-0	E(26'-0)	12.340	
212	43'-0	PO(16'-5½)	72.036	
213	43'-0	PO(16'-5½)	72.069	
215	43'-0	PO(16'-5½)	72.191	
217	43'-0	PO(16'-5½)	72.449	
218	43'-0	PO(16'-5½)	72.751	
219	43'-0	PO(16'-5½)	73.101	
220	43'-0	PO(16'-5½)	73.503	
223	43'-0	PO(16'-5½)	73.962	
224	43'-0	PO(16'-5½)	74.484	
225	43'-0	PO(16'-5½)	75.073	
226	43'-0	PO(16'-5½)	75.738	
227	43'-0	PO(16'-5½)	76.485	
229	43'-0	PO(16'-5½)	66.190	
230	43'-0	PO(16'-5½)	66.218	
231	43'-0	PO(16'-5½)	66.317	
232	43'-0	PO(16'-5½)	66.528	
233	43'-0	PO(16'-5½)	66.701	
234	43'-0	PO(16'-5½)	66.840	
235	43'-0	PO(16'-5½)	66.948	
236	43'-0	PO(16'-5½)	67.027	
237	43'-0	PO(16'-5½)	67.082	
238	43'-0	PO(16'-5½)	67.116	
239	43'-0	PO(16'-5½)	67.132	
240	43'-0	PO(37'-8½)	67.158	
465	43'-0	E(17'-7)	80.312	
761	2'-6	fE(15'-3), BOR	110.353	



Hydraulic Summary

Job Number: Route 300
Report Description: ESFR - SYSTEM 10 (10)

Job	
Job Number Route 300	Design Engineer A.Hergenreder
Job Name: Farrell Industrial Park	State Certification/License Number
Address 1 Route 300	AHJ
Address 2 Newburgh, NY	Job Site/Building
Address 3	Drawing Name FP_Rte300_Farrell_Indust_Park.cad

System	Remote Area(s)	
Most Demanding Sprinkler Data 25.2 K-Factor 159.38 at 40.000	Occupancy ESFR - SYSTEM 10	Job Suffix
Hose Allowance At Source 500.00	Pressure 40.000	Area of Application NA
Additional Hose Supplies Node	Number Of Sprinklers Calculated 12	Number Of Nozzles Calculated 0
Flow(gpm)	Coverage Per Sprinkler 100 ft²	
AutoPeak Results: Pressure For Remote Area(s) Adjacent To Most Remote Area		

Total Hose Streams 500.00			
System Flow Demand 1920.65			Total Water Required (Including Hose Allowance) 2420.65
Maximum Pressure Unbalance In Loops 0.000			
Maximum Velocity Above Ground 20.53 between nodes 177 and 1710			
Maximum Velocity Under Ground 7.25 between nodes 20 and 19			
Volume capacity of Wet Pipes 20084.36 gal			Volume capacity of Dry Pipes

Supplies

Node	Name	Hose Flow (gpm)	Static (psi)	Residual (psi) @	Flow (gpm)	Available (psi) @	Total Demand (gpm)	Required (psi)	Safety Margin (psi)
20	Water Supply	500.00	60.000	55.000	1000.00	34.341	2420.65	16.506	17.834
17	Pump		120.000	100.000	2000.00	132.037	1920.65	114.203	17.834


Pumps: Static = Churn (Pressure @ Zero Flow)

Contractor

Contractor Number 21	Contact Name Andrew Hergenreder	Contact Title Plans Department
Name of Contractor: Global Fire Prevention	Phone 845-781-0117	Extension 110
Address 1 59 Gilbert Street, Suite 101	FAX	
Address 2 Monroe, NY 10950	E-mail andrew@globalfireusa.com	
Address 3	Web-Site www.globalfireusa.com	



Water Supply at Node 20



Hydraulic Graph
Water Supply at Node 20

Static: Pressure
60.000

Residual: Pressure
55.000 @ 1000.00


Available Pressure at System Demand
34.341 @ 2420.65

Required Pressure at System Demand
16.506 @ 1920.65

Required Pressure at System Demand (Including Hose Allowance at Source)
16.506 @ 2420.65



Pump at Node 17



Hydraulic Graph	Static + Churn Pressure	Fire Pump Rating
Pump at Node 17	177.182	100.000 @ 2000.00
Static: Pressure	Fire Pump Churn Pressure	
177.182	120.000	
Residual: Pressure		
101.443 @ 1920.65		
Available Pressure at System Demand		
132.037 @ 1920.65		
Required Pressure at System Demand		
114.203 @ 1920.65		



Node Analysis

Job Number: Route 300
Report Description: ESFR - SYSTEM 10 (10)

Node	Elevation(Foot)	Fittings	Pressure(psi)	Discharge(gpm)
20	-4'-0	S	16.506	1920.65
1700	45'-0	Spr(-40.000)	40.000	159.38
1701	45'-0	Spr(-40.023)	40.023	159.42
1702	45'-0	Spr(-40.791)	40.791	160.95
1703	45'-0	Spr(-40.397)	40.397	160.17
1704	45'-0	Spr(-40.020)	40.020	159.42
1705	45'-0	Spr(-40.043)	40.043	159.46
1706	45'-0	Spr(-40.811)	40.811	160.99
1707	45'-0	Spr(-40.418)	40.418	160.21
1708	45'-0	Spr(-40.092)	40.092	159.56
1709	45'-0	Spr(-40.116)	40.116	159.61
1710	45'-0	Spr(-40.886)	40.886	161.13
1711	45'-0	Spr(-40.490)	40.490	160.35
17	2'-6	P2(-101.443)	114.203	
18	2'-6	P1	12.759	
19	-4'-0	E(26'-0)	16.090	
175	43'-0	PO(16'-5½)	73.975	
176	43'-0	PO(16'-5½)	74.014	
177	43'-0	PO(16'-5½)	74.154	
178	43'-0	PO(16'-5½)	74.453	
179	43'-0	PO(16'-5½)	74.801	
180	43'-0	PO(16'-5½)	75.199	
182	43'-0	PO(16'-5½)	75.670	
184	43'-0	PO(16'-5½)	76.220	
186	43'-0	PO(16'-5½)	76.857	
188	43'-0	PO(16'-5½)	77.590	
192	43'-0	PO(16'-5½)	64.507	
194	43'-0	PO(16'-5½)	64.536	
196	43'-0	PO(16'-5½)	64.637	
198	43'-0	PO(16'-5½)	64.851	
200	43'-0	PO(16'-5½)	65.008	
202	43'-0	PO(16'-5½)	65.118	
204	43'-0	PO(16'-5½)	65.193	
206	43'-0	PO(16'-5½)	65.238	
208	43'-0	PO(16'-5½)	65.260	
210	43'-0	PO(37'-8½)	65.294	
572	43'-0	E(17'-7)	81.605	
761	2'-6	fE(15'-3), BOR	114.097	



GLOBAL FIRE PREVENTION AUTOMATIC FIRE SPRINKLERS

The sprinkler system at Farrell Industrial Park - Route 300, Newburgh, NY has been calculated to accommodate the following:

STORAGE FOR CEILING HEIGHTS UP TO 45'-0" USING ESFR K25.0 SPRINKLERS:

COMMODITY	CONFIGURATION	RACK STORAGE (A,B)	SOLID PILED / PALLETIZED
GROUP A PLASTICS NONEXPANDED	CARTONED	40 FT	30 FT
	EXPOSED	25 FT	30 FT
CLASS IV	NON-ENCAPSULATED(D)	40 FT	35 FT
CLASS I - III	NON-ENCAPSULATED(D)	40 FT	35 FT
IDLE WOOD PALLETS	STACKED ON FLOOR	20 FT	25 FT

IMPORTANT: A MINIMUM CLEARANCE OF 36" BETWEEN THE SPRINKLER DEFLECTOR AND THE TOP OF STORAGE MUST BE MAINTAINED

FOOTNOTES:

- (A) Solid Shelf Racks: Will require in-rack sprinklers depending on the cubic feet of the shelf area (See Sec 16.1.6)
- (B) Must comply with Flue Requirements in accordance with NFPA 13
- (D) Pallets of goods are not to be wrapped on the top with plastic sheeting with greater than 50% coverage.

GENERAL RACK STORAGE NOTES:

1. Racks are to be Single or Double row open grate racking, with a minimum of 8'-0" aisles between racks.
2. No longitudinal flue space required between racks. 6" nominal transverse flue spaces shall be maintained at all rack uprights.
3. Column Protection not required per NFPA 13, 16.1.4.1
4. Open top containers of all commodities shall not be stored over 12ft.

UNLESS NOTED OTHERWISE ALL AREAS WITH OCCUPANCIES HAVING USES AND CONDITIONS SIMILAR TO THE FOLLOWING:

HAZARD CLASSIFICATION	OCCUPANCY EXAMPLES
LIGHT HAZARD	<ul style="list-style-type: none"> • OFFICES, INCLUDING DATA PROCESSING
ORDINARY HAZARD GROUP 1	<ul style="list-style-type: none"> • BEVERAGE MANUFACTURING • DAIRY PRODUCTS MANUFACTURING AND PROCESSING • GLASS AND GLASS PRODUCTS MANUFACTURING
ORDINARY HAZARD GROUP 2	<ul style="list-style-type: none"> • CONFECTIONARY PRODUCTS • MACHINE SHOPS • RESIN APPLICATION AREAS • TEXTILE MANUFACTURING • WOOD MACHINING/PRODUCT ASSEMBLY